


• S4 OMMITTED  
 • B13 OMMITTED  
 • ALL SLAB 125 THK. ACCEPT OTHERWISE SPECIFIED  
**FIRST FLOOR SLAB LEVEL LAYOUT (+7800)**

SLAB NO.	SLAB THK.
S1	150 mm THK.
S5	150 mm THK.
S12	200 mm THK.

SYMBOL	SLAB STEEL
A	10T @ 150 C/C ALT B UP
B	8T @ 125 C/C ALT B UP
C	10T @ 125 C/C DIST.
D	8T @ 150 C/C ALT B UP
E	10T @ 300 C/C EXT. TOP
F	10T @ 100 C/C ALT B UP
G	8T @ 175 C/C DIST.
H	8T @ 150 C/C STRAIGHT
I	12T @ 100 C/C CHIPIYA

THIS DRAWING IS THE PROPERTY OF "SILICON" STRUCTURALS AND SHOULD NOT BE USED FULLY OR PARTLY FOR ANY OTHER PURPOSE OTHER THAN THAT ISSUED FOR WITHOUT THE PRIOR PERMISSION. ALL DIMENSIONS ARE TO BE READ AND NOT TO BE MEASURED. ALL DIMENSIONS ARE IN MILLIMETERS. PLEASE REFER CORRESPONDING STRUCTURAL/OTHER SERVICES DRAWINGS ALONG WITH THIS DRAWING. ANY AMBIGUITY FOUND SHOULD BE BROUGHT TO ARCHITECT'S NOTICE IMMEDIATELY.

1	02-01-2010	FOR EXECUTION	06
NO	DATE	PRINTS ISSUED	DISTRIBUTION
DISTRIBUTION OF COPY			
REVISIONS			
NO	DATE	REMARKS	BY




LEGEND :

BRICK WALL  
 R.C.C. COLUMN  
 R.C.C. RETAINING WALL

NOTE :

- \* ALL DIMENSIONS ARE IN MM. & TO BE VERIFIED WITH ARCH. DWG.
- \* APPROVED MIX CONCRETE DESIGN OF GRADE M-20 SHOULD BE USED UNLESS SPECIFIED.
- \* Fe 415 REINFORCEMENT (TMT BARS) SHOULD CONFIRM IS:1786-2000.
- \* CLEAR COVER TO REINFORCEMENT SHALL BE 25mm IN BEAM 20mm IN SLABS, 40mm IN COLUMN, 50mm IN FOOTING
- \* ANY DISCREPANCY IN DRAWING SHALL BE BROUGHT TO THE NOTICE OF DESIGN ENGINEER.
- \* DRAWING TO BE READ WITH ARCH.SUPPORT DRG.
- \* STRUCTURE IS DESIGNED FOR GROUND + TWO FLOORS ONLY WITH FUTURE PROVISION OF ONE FLOOR
- \* THE BLDING IS DESIGNED FOR ZONE-III AS PER IS:456-2000, IS:1893-2002



CLIENT:  
**CADILA HEALTHCARE LTD.**  
 AHMEDABAD.

PROJECT:  
**ZYDUS CENTRE FOR EXCELLENCE,**  
 AHMEDABAD

PROJECT NO:	DWG. NO.:
104-09	INS-ST-11

DWG. TITLE :  
**PHASE - I**  
**INSTITUTE BLOCK**  
**FIRST FLOOR SLAB LVL LAYOUT**

SCALE : 1:100  
 DATE : 02-01-2010  
 DEALT : RSP  
 PATH : -

ARCHITECT:  
**SNEHAL SHAH**  
 1/B, AVANTIKA SOCIETY,  
 NARANPURA,  
 AHMEDABAD-380 013,  
 INDIA.  
 TELE: (079) 2768 3001/02/03.  
 FAX: (079) 2768 3004.  
 e-mail : studio@snehalshaharchitect.com

STRUCTURAL ENGINEER :  
**" SILICON "**  
**ENGINEERING CONSULTANTS PVT LTD.**  
**DIPAK BHAVSAR**  
 315/ Patel Avenue, Near Gurudwara  
 S.G.Highway Thaltej  
 Ahmedabad 380059  
 e-mail: dipak@siliconoutsourcing.net  
 Ph: +91-7940031887