



GENERAL NOTES		PRINT SCHEDULE		REVISION		DRAWING TITLE		CONSULTANTS	
ALL DIMENSIONS ARE IN MM. & TO BE VERIFIED WITH ARCH. DWG. ANY DISCREPANCY IN DRAWING SHALL BE BROUGHT TO THE NOTICE OF DESIGN ENGINEER. APPROVED MIX CONCRETE DESIGN OF GRADE M:20 SHOULD BE USED UNLESS SPECIFIED. Fe 415 REINFORCEMENT (TMT BARS) SHALL CONFORM IS:1786-2000. CLEAR COVER TO REINFORCEMENT SHALL BE 25mm IN BEAM 20mm IN COLUMN, 50mm IN FOOTING. DEPTH OF FOUNDATION SHOULD BE MINIMUM 1.2 MT OR UP TO GOOD SOIL FROM EXISTING NATURAL GROUND LEVEL.		DATE: _____ NO. OF PRINT: _____ CLIENT: _____ CONTRACTOR: _____ P.M.C.: _____ OTHERS: _____		DATE: _____ NO. OF REVISION: _____ DESCRIPTION: _____		DRAWING TITLE: WORKSHOP FOUNDATION DETAILS-1 SCALE: AS SHOWN (A1) DRAWN BY: NIKHIL DATE: 09-04-2014		STRUCTURE SILICON ENGINEERING CONSULTANTS PVT LTD	